


SECTION B-B



SECTION A-A



- NOTES:
1. SEPTIC TANKS MANUFACTURED AND TESTED IN ACCORDANCE WITH AS/NZS 1546.1:2008
 2. AIR PUMP CAPACITY: 2 x 200L/min
 3. GROWTH MEDIA TOTAL SURFACE AREA: 160m²

GENERAL TOLERANCES UNLESS OTHERWISE STATED:	
HOLES	+0.3 -0.0
FOLDING	+0.5 -0.5
LENGTH	TOLERANCE
-6	6 0.1
6	30 0.2
30	120 0.3
120	315 0.5
315	1000 0.8
1000	>1000 1.0
ALL ANGLES	0.5°

Econocycle
AERATED WASTEWATER TREATMENT SYSTEMS

COPYRIGHT
THIS DRAWING AND INFORMATION CONTAINED HEREIN REMAINS THE COPYRIGHT PROPERTY OF ECONOCYCLE AND CANNOT BE COPIED OR REPRODUCED WITHOUT WRITTEN PERMISSION.

SCALE: DO NOT SCALE

DRAWN BY: P MCKAY
MODELLED BY: P MCKAY

PROJECT	MAXI 45 SYSTEM
TITLE	MAXI 45 SYSTEM
PROCESS	
DATE PLOTTED	28/01/2011
DRAWING LAST MODIFIED BY	P MCKAY
MODEL LAST MODIFIED BY	P MCKAY

COAT/TREAT:		SHEET SIZE	A2
PART#	124_2700	REVISION	1.1
		SHEET No.	1 OF 1