


ACCREDITED
11 AUG 2022
NSW MINISTRY OF HEALTH

NOTES:

1. SEPTIC TANKS TO BE MANUFACTURED AND TESTED IN ACCORDANCE WITH AS/NZS 4541:2008
2. CONCRETE STRENGTH = 40MPa
3. CONCRETE TO BE VIBRATED TO ENSURE WELL COMPACTED CONCRETE
4. TANKS TO BE REINFORCED WITH FIBRE STEEL
5. LIFTING TO BE "REID SWIFT LIFTS" 4 x 2.5 TONNE FOOT ANCHORS CAST INTO BASE OF THE TANK, 3 x 4.3 TONNE ANCHORS CAST INTO TANK LIDS

 ECONOCYCLE AERATED WASTEWATER TREATMENT SYSTEMS		PROJECT: COLLECTION WELL TITLE: 3750L CONCRETE TANK ASSY NSW HEALTH CERTIFICATION DRAWING		SHEET SIZE: A3	
		UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN MM		CON./REV. - PART # -	
SCALE: 1:10 NOT SCALE DRAWN BY: P. MCKAY CHECKED BY: P. MCKAY		DATE PLOTTED: 27/07/2010 DRAWING LAST MODIFIED BY: P. MCKAY MODEL LAST PLOTTED BY: P. MCKAY		REVISION: 124-1610 1B 1 OF 1	
COPYRIGHT © 2010 ECONOCYCLE 100 WILSON ROAD WILSON PROMENADE WILSON PROMENADE WILSON PROMENADE					